

AL008 Phase sequ.prot.alarm

SPRSUN

Cause analysis

Abnormal parameter setting.

Solution

Set DI5 of Ot6 page in M09 to NO.

