

AL013 Low superheat - Vlv.A

AL115 EEV alarm:Low superheat

SPRSUN

Cause analysis

- The unit has heavy frost.
- The unit has been operating at low frequency for a long time.



Detection method

- Visually check whether the unit is heavy frosted.
- Check whether the operating frequency of the unit in the user parameters is consistent with low frequency operation

AL013 Low superheat - Vlv.A

AL115 EEV alarm:Low superheat

SPRSUN



Solution

- If the frost is heavy, pls move the ambient sensor on the evaporator away from the evaporator.



AL013 Low superheat - Vlv.A



AL115 EEV alarm:Low superheat



Solution

- If there is no frost on the unit, pls change the Alarm delay parameter on the EEV n 1 page in the factory parameter M07 to 18000s

