

# AL037 BLDC-alarm:Out of Envelope

**SPRSUN**



## Cause analysis

The water temperature is too high or the ambient temperature is too low.

## Detection method

Check whether the user parameter B3 is lower than -25 degrees, and whether B1 exceeds 61 degrees.

## Solution

Operate within the allowable operating range.